
CERTIFICATE OF APPROVAL

No CAF 119

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

**Designated CERTIFIRE Approved Door and Blank Manufacturers
as Converted by**

MIDLAND BUILDING PRODUCTS LIMITED

**Unit 10, Spartan Industrial Centre, Brickhouse Lane
Great Bridge, West Midlands, B70 0DH
Tel: 0121 522 4114 Fax: 0121 522 3123**

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:


SCOPE OF APPROVAL

Approved for processing* of fire
doors and/or blanks
manufactured by CERTIFIRE
approved companies as specified
in this certificate: Blank
conversion, apertures; glazing of
apertures and door frames

TECHNICAL SCHEDULE

**TS10 Fire Resisting Door
Assemblies with non- Metallic
Leaves**

**Signed and sealed for and on behalf of Exova (UK) Limited trading as
Warrington Certification**



**Sir Ken Knight
Chairman
Impartiality Committee**



**Paul Duggan
Certification Manager**



Issued: 9th November 2000
Revised: 8th November 2016
Valid to: 1st February 2021

Page 1 of 5



CERTIFICATE No CAF 119

MIDLAND BUILDING PRODUCTS LIMITED

GLAZED APERTURES and DOOR FRAMES (Premdor Crosby Limited)

1. This approval relates to the cutting of apertures with or without glazing in doors supplied by Premdor Crosby Limited and to the manufacture of doorframes. Subject to the undermentioned conditions, the doors will meet the requirements as detailed in the relevant certificates.
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Technical Handbook (Scotland), Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
3. The certified doors for which the cutting of apertures, subsequent glazing thereof and provision of frames is approved are as following:

Premdor Crosby Certificate No	Timber Door Product	Aperture Cutting	Glazing of Apertures	Manufacture of Frames	MDF Frames	Resizing & Relipping
CF195	Premdor Fireshield	✓	✓	✓	✓	✗
CF198	FD30 Moulded Skin Chipboard Core	✓	✓	✓	✓	✗
CF240	FD30 Premcore	✓	✓	✓	✓	✓
CF241	FD60 Premcore	✓	✓	✓	✗	✓
CF302	FD60 Flaxcore	✗	✗	✓	✗	✗
CF380	FD30 Tubecore Lite	✓	✓	✓	✓	✗
CF625	FD30 PremCORE Lite (L)	✓	✓	✓	✓	✓

Note: The scope of approval and field of application for the doors is contained in the above referenced certificates.

4. Apertures, glazing and frames shall be in accordance with Premdor Crosby Limited construction specifications and data sheets for the above referenced products.
5. Processing is conducted in accordance with Premdor Crosby Limited procedures.
6. The process is approved on the basis of on-going certification of quality management system to ISO 9001:2008.
7. Inspection and surveillance of factory production control
8. The approval relates to on-going production.
9. Approved products carry both the original manufacturer's CERTIFIRE approval label and a second label identified with the processor's name and contact number, the CERTIFIRE name, or name and mark, together with the CERTIFIRE certificate number and a unique serial number.

CERTIFICATE No CAF 119

MIDLAND BUILDING PRODUCTS LIMITED

GLAZED APERTURES and DOOR FRAMES (JELD-WEN Limited)

1. This approval relates to the cutting of apertures with or without glazing in doors supplied by JELD-WEN Limited and to the manufacture of doorframes. Subject to the undermentioned conditions, the doors will meet the requirements as detailed in the relevant certificates.
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Technical Handbook (Scotland), Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
3. The certified doors for which the cutting of apertures, subsequent glazing thereof and provision of frames is approved are as following:

JELD-WEN Certificate Number	Timber Door Product	Aperture Cutting	Glazing of Apertures	Manufacture of Frames	MDF Frames	Resizing
CF160	FD30 Flush & Die Formed	✓	✓	✓	✓	✗
CF177	FD60 Flush	✓	✓	✓	✗	✗
CF192	FD30 Tubeboard	✓	✓	✓	✓	✗
CF179	FD60 Die-formed	✗	✗	✓	✗	✗
CF271	FD30 Doors	✓	✓	✓	✗	✗
CF331	FD60 Doors	✗	✗	✓	✓	✓
CF433	FD30 Doors	✗	✗	✓	✓	✗
CF572	FD30 Doors	✗	✗	✓	✓	✗
CF573	FD30 Doors	✗	✗	✓	✓	✗
CF5143	FD30 Doors	✓	✓	✓	✓	✓

Note: The scope of approval and field of application for the doors is contained in the above referenced certificates.

4. Apertures, glazing and frames shall be in accordance with JELD-WEN UK Limited construction specifications and data sheets for the above referenced products.
5. Processing is conducted in accordance with JELD-WEN UK Limited procedures.
6. The process is approved on the basis of on-going certification of quality management system to ISO 9001:2008.
7. Inspection and surveillance of factory production control
8. The approval relates to on-going production.
9. Approved products carry both the original manufacturer's CERTIFIRE approval label and a second label identified with the processor's name and contact number, the CERTIFIRE name, or name and mark, together with the CERTIFIRE certificate number and a unique serial number.

Page 3 of 5 Signed
E/144



Issued: 9th November 2000
Revised: 8th November 2016
Valid to: 1st February 2021

CERTIFICATE No CAF 119

MIDLAND BUILDING PRODUCTS LIMITED

GLAZED APERTURES and DOOR FRAMES (Vicaima Limited)

1. This approval relates to the cutting of apertures with or without glazing in doors supplied by Vicaima Limited and to the manufacture of doorframes. Subject to the undermentioned conditions, the doors will meet the requirements as detailed in the relevant certificates.
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Technical Handbook (Scotland), Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
3. The certified doors for which the cutting of apertures, subsequent glazing thereof and provision of frames is approved are as following:

Vicaima Certificate No	Timber Door Product	Aperture Cutting	Glazing of Apertures	Manufacture of Frames	MDF Frames	Resizing
CF218	FD30 'SDC'	✓	✓	✓	✓	x
CF454	FD60	✓	✓	✓	✓	x

Note: The scope of approval and field of application for the doors is contained in the above referenced certificates.

4. Apertures, glazing and frames shall be in accordance with Vicaima Limited construction specifications and data sheets for the above referenced products.
5. Processing is conducted in accordance with Vicaima Limited procedures.
6. The process is approved on the basis of on-going certification of quality management system to ISO 9001:2008.
7. Inspection and surveillance of factory production control
8. The approval relates to on-going production.
9. Approved products carry both the original manufacturer's CERTIFIRE approval label and a second label identified with the processor's name and contact number, the CERTIFIRE name, or name and mark, together with the CERTIFIRE certificate number and a unique serial number.

CERTIFICATE No CAF 119

MIDLAND BUILDING PRODUCTS LIMITED

GLAZED APERTURES and DOOR FRAMES (ZMR Limited, Trading as Millennium Door Systems)

1. This approval relates to the cutting of apertures with or without glazing in doors supplied by supplied by ZMR Limited (Trading as Millennium Door Systems) and to the manufacture of door frames. Subject to the undermentioned conditions, the doors will meet the requirements as detailed in the relevant certificates.
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Technical Handbook (Scotland), Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
3. The certified doors for which the cutting of apertures, subsequent glazing thereof and provision of frames is approved are as following:

ZMR Ltd Certificate Number	Timber Door Product	Sizing and lipping	Aperture Cutting	Glazing of Apertures	Manufacture of Frames	MDF Frames
CF819	FD30 Strebord 44	✓	✓	✓	✓	✓
CF820	FD60 Strebord 54	✓	✓	✓	✓	✓

Note: The scope of approval and field of application for the doors is contained in the above referenced certificates.

4. Lippings, apertures, glazing and frames shall be in accordance with ZMR Limited (Trading as Millennium Door Systems) construction specifications and data sheets for the above referenced products.
5. Processing is conducted in accordance with ZMR Limited (Trading as Millennium Door Systems) procedures.
6. The process is approved on the basis of on-going certification of quality management system to ISO 9001:2008.
7. Inspection and surveillance of factory production control
8. The approval relates to on-going production.
9. Approved products carry a label identified with the blank manufacturers certificate number, the processor's name and contact number, the CERTIFIRE name, or name and mark, together with the CERTIFIRE certificate number and a unique serial number.

Page 5 of 5 Signed
E/144



Issued: 9th November 2000
Revised: 8th November 2016
Valid to: 1st February 2021